

## SERIES FP INTUMESCENT FIRESTOP PLUG




### PHYSICAL PROPERTIES

PROPERTIES:	SERIES FP INTUMESCENT FIRESTOP PLUG
Color	Red
Nominal Density	19 pcf (304 kg/m <sup>3</sup> )
Weight	2 in. – 0.20 lb (91 g) 4 in. – 0.50 lb (227 g)
Expansion Begins	350° F (176° C)
Volume Expansion	10 X
In-Service Temperature	<130° F (54° C)
Shelf Life	N.A.
VOC Content	N.A.

### SPECIFICATIONS

The firestopping system shall utilize an intumescent foam plug having a nominal density of 19 pcf. The plug shall expand a minimum 10 times. The one-piece product shall be sized to fit the inside diameter of the opening or sleeve. The plug shall be UL Classified and tested to the requirements of ASTM E814 (UL1479) and CAN/ULC S115.



FILL, VOID OR CAVITY MATERIALS FOR USE IN THROUGH-PENETRATION FIRESTOP SYSTEMS. SEE UL FIRE RESISTANCE DIRECTORY.

3L73

SPECIFIED DIVISIONS		
Division	Section	Title
7	07 84 00	Firestopping
26	26 00 00	Electrical
27	27 00 00	Communications

### MAINTENANCE

Installations should be inspected periodically for subsequent damage.

### PRECAUTIONARY INFORMATION

No unusual hazards are known or expected. Observe normal safety procedures during installation.

## FP500D FIRESTOP PLUG



### PHYSICAL PROPERTIES

PROPERTIES:	SERIES FP INTUMESCENT FIRESTOP PLUG
Color	Red
Nominal Density	19 pcf (304 kg/m <sup>3</sup> )
Weight	.50 lb (225 g)
Expansion Begins	350° F (176° C)
Volume Expansion	10 X
In-Service Temperature	<130° F (54° C)
Shelf Life	No Limit
VOC Content	N.A.

### SPECIFICATIONS

The firestopping system shall utilize an intumescent foam plug having a nominal density of 19 pcf. The plug shall expand a minimum 10 times. The one-piece product shall be sized to fit the inside diameter of the opening or sleeve. The plug shall be UL Classified and tested to the requirements of ASTM E814 (UL1479) and CAN/ULC S115.



#### SpecSeal Series FP500D Firestop Plug

FILL, VOID OR CAVITY MATERIALS CERTIFIED FOR USE IN THROUGH-PENETRATION FIRESTOP SYSTEMS. SEE UL ONLINE CERTIFICATIONS DIRECTORY.

SPECIFIED DIVISIONS		
Division	Section	Title
7	07 84 00	Firestopping
22	22 00 00	Plumbing

### PRECAUTIONARY INFORMATION

No unusual hazards are known or expected. Observe normal safety procedures during installation.

### MAINTENANCE

Installations should be inspected periodically for subsequent damage.